

**RETLIF TESTING LABORATORIES**  
**101 New Boston Road**  
**Goffstown, NH 03045**

**CERTIFICATE OF CONFORMANCE**  
**EN 61326:1997/A1:1998/A2:2001/A3:2003**

Date of Compliance: March 13, 2007

Issued To: ControlAir, Inc.  
8 Columbia Drive  
Amherst, NH 03031

Reference: Retlif Report Number R-4646N, Rev. A

*RETLIF TESTING LABORATORIES hereby acknowledges that compliance testing in accordance with the below listed standards was performed on a representative sample of the equipment listed below. RETLIF TESTING LABORATORIES further acknowledges that the test sample listed below was found to be in compliance with these standards. This certificate is hereby issued to the above named grantee and is valid only for the equipment identified below.*

*Manufacturer:* ControlAir, Inc.  
*Equipment Tested:* T590 Transducer  
*Model:* T590  
*Brand Name:* Control Air

Note(s):

- 1) See attached report R-4646N for details and/or conditions pertaining to this certificate.
- 2) Conforms to the emissions requirements of EN 61326:1997/A1:1998/A2:2001/A3:2003:  
Class A, Radiated Emissions, 30MHz to 1GHz
- 3) Conforms to the immunity requirements of EN 61326:1997/A1:1998/A2:2001/A3:2003:  
EN61000-4-2:1995/A1:1998/A2:2001 Electrostatic Discharge, 8kV Direct Air, 4kV Direct and Indirect Contact  
EN61000-4-3: 2002/A1:1998/A2:2001 Radiated RF Immunity, 80MHz-1GHz, 10V/m, 80% AM 1kHz  
Radiated RF Immunity, 1.4MHz-2GHz, 3V/m, 80% AM 1kHz  
Radiated RF Immunity, 2GHz-2.7GHz, 1V/m, 80% AM 1kHz  
EN61000-4-4:2004 EFT, 2kV Direct to Power Leads  
EN61000-4-5:1995/A1:2001 Surge Immunity, 1.0kV Differential Mode  
EN61000-4-6:1996/A1:2001 Conducted RF Immunity, 150kHz-80MHz, 3Vrms, 80% AM 1kHz  
Conducted RF Immunity, 150kHz-80MHz, 10Vrms, 80% AM 1kHz  
EN 61000-4-8:1994/A1:2001 Power Frequency Magnetic Field Immunity, 30 Amps/m at 50Hz