

Supplement 1 to  
EC-Type Examination Certificate No. FM08ATEX0049X  
in accordance with Clause 6 of Annex III to Directive 94/9/EC.

Equipment or protective system:  
(Type Reference and Name) **T595XP Current-to-Pressure Transducer**

Name of Applicant: **ControlAir Inc.**

Address of Applicant: **8 Columbia Drive  
Amherst, NH 03031  
USA**

The examination and test results are recorded in confidential report number 3035877EC dated 16<sup>th</sup> April 2009

Description of the supplements and modifications:


10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.

14 **Special Conditions for Safe Use:**

*The User shall permanently mark the protection type chosen. Once the type of protection has been marked it shall not be changed.*

17 **Approved Drawings**

Drawing No:	Rev	Title / Description
429-990-060 sheets 1 & 2	3-26-09	XP Certification Drawing T595XP Transducer
441-622-099	04/07/09	Type 595XP Installation, Operation and Maintenance Instructions



**Andrew Was**  
Certification Manager, FM Approvals Ltd.

Issue date: 17<sup>th</sup> April 2009

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**