

Declaration of Conformity

According to ISO/IEC Guide 22 and BS 7514

Manufacturer's Name: Control Air Inc.

Model Numbers: 8 Columbia Drive, Amherst, New Hampshire 03031, USA

The manufacturer hereby declares that the product

Product Name: Transducer Families
Model Numbers: Type 550-XXX, 900-XXX and 950-XXX
Product Options: All Pressure Ranges from 0 to 120 PSIG
where stated accuracy is as follows:
550-XXX 1% of span
900-XXX .10% of span
950-XXX .25% of span

Conforms to the following standards or other normative documents:

Electromagnetic Emissions: EN 55011A:1988
(by Council Directive 89/335/EEC) CISPR 22:1985 Class A

Electromagnetic Immunity: EN 50082-1:1998 + A1
(by Council Directive 89/336/EEC)

Safety: EN 61010-1:1993 + AMD 2:1995

Supplementary Information:

Please note, in reference to these Models listed above for this Company's Product Line, that the DC power supply is not supplied by this manufacturer. Any or all DC power supplies used to power these models must be **CE** approved and validated to EN 50082-1:1998 or equal. During testing for Electromagnetic Immunity it was determined that all models listed above were compliant to standards listed above when tested with a **CE** approved DC power supply. If the purchaser of these products chooses a substandard DC power supply, the manufacturer specified tolerance range of the product will be void and the intended operation of the product may deviate from the intended design/operation of the product.


When and Where Issued

June 10, 2002
Amherst, New Hampshire USA

Marks of Compliance



Integrity Design & Test
37-7 Ayer Road
Littleton, Massachusetts 01460
USA
866-446-4387



Jim Doyle
VP of Engineering & Quality
Control Air Inc.
8 Columbia Drive
Amherst, New Hampshire 03031
USA
603-889-1844