



Controlair, LLC
 8 Columbia Dr
 Amherst NH 03031
 United States

Certificate of Compliance to IEC 61508

FM Approvals
 Certifies herewith that the

Type 6100/6200 Volume Booster
 (Safety Manual 441-622-208)

Complies with the relevant requirements of standards listed below:

Standards	Description	Compliance
IEC 61508-1: 2010	Functional Safety of Electrical/Electronic/Programmable Electronic Safety-Related Systems - General Requirements	Part 1
IEC 61508-2: 2010	Functional Safety of Electrical/Electronic/Programmable Electronic Safety-Related Systems	Part 2

And therefore

**IS DECLARED "FIT FOR USE" IN A SIL 3, 2 or 1
 Low Demand SAFETY APPLICATION**

Models	Type	SIL	HFT	SFF	PFD	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Type 6100/6200	Type A Pneumatic Component	3, 2, 1	0	94%	4.78×10^{-6}	8.06×10^{-9}	9.13×10^{-9}	9.06×10^{-9}	1.07×10^{-9}

Note: PFD Average calculation is based on a proof test interval of 1-year, a Hardware Fault Tolerance (HFT) of 0, a Mean Time of Repair (MTR) of 8 hours, and Mean Time To Restoration (MTTR) of 8 hours.

Specific Condition of Use:

- 1) The analysis shows the design of the Type 6100/6200 Volume Booster can meet the hardware requirements of IEC61508 SIL 3 depending on the complete final element design.
- 2) 1oo1 Low Demand Configuration.

*This certificate is subject to conditions of use presented in FM Approval Report
 Project ID PR456578 dated 28th September 2020.*



J.E. Marquedant
 James E. Marquedant
 Manager - Electrical Systems
 FM Approvals
 One Technology Way,
 Norwood MA, 02062 USA

24 June 2024

Date